



2010 DRINKING WATER REPORT

The City of Blaine is issuing the results of monitoring done on its drinking water for the period from Jan. 1 to Dec. 31, 2010. The purpose of this report is to advance consumers' understanding of drinking water and heighten awareness of the need to protect precious water resources.

SOURCE OF WATER

The City of Blaine provides drinking water to its residents from a groundwater source: 16 wells, ranging from 228 to 741 feet deep, drawing water from the Franconia-Mt. Simon, Franconia-Eau Claire, Quaternary Buried Artesian, Iron-ton-Mt. Simon, Jordan-Mt. Simon and Jordan-Galesville aquifers.

The water provided to customers may meet drinking water standards, but the Minnesota Department of Health has also made a determination as to how vulnerable the source of water may be to future contamination incidents. If you wish to obtain the entire source water assessment regarding your drinking water, please call 651-201-4700 or 1-800-818-9318 (and press 5) during normal business hours. It can also be viewed online at www.health.state.mn.us/divs/eh/water/swp/swa.

Call 763-785-6165 if you have questions about the City of Blaine drinking water or would like information about opportunities for public participation in decisions that may affect the quality of the water.

RESULTS OF MONITORING

No contaminants were detected at levels that violated federal drinking water standards. However, some contaminants were detected in trace amounts that were below legal limits. The following table shows the contaminants detected in trace amounts last year. (Some contaminants are sampled less frequently than once per year; as a result, not all contaminants were sampled for in 2010. If any of these contaminants were detected the last time they were sampled for, they are included in the table along with the date that the detection occurred.)

ABBREVIATION KEY FOR TABLES

MCLG — Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

MCL — Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

MRDL — Maximum Residual Disinfectant Level.

MRDLG — Maximum Residual Disinfectant Level Goal.

AL — Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirement which a water system must follow.

90th Percentile Level — This is the value obtained after disregarding 10 percent of the samples taken that had the highest levels. (For example, in a situation in which 10 samples were taken, the 90th percentile level is determined by disregarding the highest result, which represents 10 percent of the samples.) Note: In situations in which only five samples are taken, the average of the two with the highest levels is taken to determine the 90th percentile level.

pCi/l — PicoCuries per liter (a measure of radioactivity).

ppb — Parts per billion, which can also be expressed as micrograms per liter (µg/l).

ppm — Parts per million, which can also be expressed as milligrams per liter (mg/l).

nd — No detection.

N/A — Not applicable (does not apply).

Contaminant (units)	MCLG	MCL	Level Found		Typical Source of Contaminant
			Range (2010)	Average Result*	
1,2-Dichloroethane (ppb)	0	5	0.6-0.67	0.67	Discharge from industrial chemical factories.
Alpha Emitters (pCi/l)	0	15.4	N/A	7.7	Erosion of natural deposits
Arsenic (ppb)	0	10	1.55-10.4	10.4**	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.
Barium (ppm)	2	2	N/A	0.05	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Combined Radium (pCi/l)	0	5.4	N/A	3.3	Erosion of natural deposits
Flouride (ppm)	4	4	N/A	1.2	State of Minnesota requires all municipal water systems to add fluoride to the drinking water to promote strong teeth; erosion of natural deposits; discharge from fertilizer and aluminum factories.
Haloacetic Acids (HAA5) (ppb)	0	60	N/A	9.1	By-product of drinking water disinfection.
Mercury (inorganic) (ppb)	2	2	N/A	0.02	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
TTHM (total trihalomethanes) (ppb)	0	80	N/A	18.4	Byproduct of drinking water disinfection.
Total Coliform Bacteria	0 present	>5% present	N/A	2%***	Naturally present in environment.
Xylenes (ppm)	10	10	nd-0.00159	0.002	Discharge from petroleum factories; discharge from chemical factories.

*This is the value used to determine compliance with federal standards. It sometimes is the highest value detected and sometimes is an average of all the detected values. If it is an average, it may contain sampling results from the previous year.

**Our system has taken the initiative to limit the amount of water being pumped from the source(s) with elevated arsenic. Our system has signed a compliance agreement with the MDH that ensures all residents receive drinking water that contains less than 10.4 ppb of arsenic on a regular basis.

Erosion of natural deposits may lead to arsenic in groundwater. Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an elevated risk of getting cancer.

***Follow-up sampling showed no contamination present.

Contaminant (units)	MRDLG	MRDL	***	****	Typical Source of Contaminant
Chlorine (ppm)	4	4	0.04-1.79	0.59	Water additive used to control microbes.

*** Highest and lowest monthly average.

**** Highest quarterly average.

Contaminant (units)	MCLG	AL	90% Level	Sites over AL	Typical Source of Contaminant
Copper (ppm)	1.3	1.3	0.93	0 of 30	Corrosion of household plumbing systems; erosion of natural deposits.
Lead (ppb)	N/A	15	0.8	0 of 30	Corrosion of household plumbing systems; erosion of natural deposits.

If present, infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Blaine is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information about lead in drinking water, testing methods and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at 1-800-426-4791 or online at www.epa.gov/safewater/lead.

Some contaminants do not have an established Maximum Contaminant Levels. These unregulated contaminants are assessed using state standards known as health risk limits to determine if they pose a threat to human health. If unacceptable levels of an unregulated contaminant are found, the response is the same as if an MCL has been exceeded; the water system must inform its customers and take other corrective actions. The table that follows shows the unregulated contaminants detected:

Contaminant (units)	Range (2010)	Average Result	Typical Source of Contaminant
Sodium (ppm)	N/A	10.5	Erosion of natural deposits.
Sulfate (ppm)	N/A	11.4	Erosion of natural deposits.

CONTACT US

Residents can call the City of Blaine Public Works desk at 763-785-6165 for more information about drinking water in the community. Use the same number for additional information about opportunities to participate in decisions that may affect water quality.

In case of an after-hours emergency concerning the water system, please call Anoka County Emergency Dispatch at 763-427-1212.

John Lind
Water Department
Supervisor
763-785-6137

jlind@ci.blaine.mn.us

Mike Ulrich
Public Works Director
763-785-6167

mulrich@ci.blaine.mn.us

COMPLIANCE WITH NATIONAL PRIMARY DRINKING WATER REGULATIONS

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff and septic systems.

Radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, the U. S. Environmental Protection Agency (EPA) prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline at 1-800-426-4791. ■